



## INSPECTION BODY ACCREDITATION PROGRAM (IBAP)

### Scope of Accreditation

**Accredited Legal Entity:** Electrical Safety Authority operating as ESAFE

Contact Name: Jacques Martin

Address: 155A Matheson Boulevard West  
Mississauga, Ontario L5R 3L5

Operating from: 4043 Carling Avenue, Suite 106  
Ottawa, Ontario K2K 2A4

Telephone: +1 613 271 1489

Fax: +1 613 271 6441


Website: <http://www.esafieldevaluation.ca>

Email: [jacques.martin@electricalsafety.on.ca](mailto:jacques.martin@electricalsafety.on.ca)

<b>Accreditation Number:</b>	06003
<b>Initial Accreditation Date:</b>	2005-03-29
<b>Reaccreditation Date:</b>	2017-07-05
<b>Accreditation Expiry Date:</b>	2021-03-29
<b>Accreditation Standards:</b>	ISO/IEC 17020:2012 SCC Requirements and Guidance, Inspection Body Accreditation Program
<b>Accreditation Sub-programs:</b>	SPE-1000 Field Evaluation/Special Inspection SPE-3000 Field Evaluation/Special Inspection

## SPE-1000 Field Evaluation/Special Inspection

### Inspection Label



**"P" Series - Approval of electrical panels only. "S" Series - On all other electrical equipment.**

**Note:** The labels presented above are in accordance with CSA-SPE-1000 and are effective as of April 01, 2010.

### Scope of Accreditation:



The performing of field evaluations/special inspections and the application of approval labels on electrical equipment and systems in accordance with all of the following:

As identified in the scope of CSA SPE-1000 Model Code for the field evaluation/special inspection of electrical equipment, but excluding:

- wire and cable products;
- wiring devices;
- equipment for use in hazardous locations;
- medical electrical equipment and systems;
- components\* that will require further evaluation as part of a complete assembly, such as switches, relays, and timers;
- equipment connected to line voltage in excess of 46 kV;
- manlifts, elevators, climb assists and similar systems (other than their associated control panels); and
- any equipment that is not permitted to be field evaluated as directed by an AHJ (such as air-cleaning equipment that intentionally produces ozone).

\* Special inspection/field evaluation only applies to equipment that is capable of being connected to the supply in accordance with the Canadian Electrical Code, Part I.

Product inspected to CSA SPE-1000 prior to April 01, 2010 was labeled in accordance with CSA-SPE-1000-99 as represented by the labels below.



**"P" Series - Approval of electrical panels only "S" Series - On all other electrical equipment.**

## SPE-3000 Field Evaluation/Special Inspection

### Inspection label



“M” Series – Approval of medical equipment or systems

### Scope of Accreditation:

The performing of field evaluations/special inspections and the application of approval labels on medical-electrical equipment (MEE) and medical-electrical systems (MES)\* in accordance with all of the following:

As identified in the scope of CSA SPE-3000 Model Code for the field evaluation/special inspection of medical electrical equipment and systems, but excluding the following product categories at this time:

- a) cosmetic and hygiene equipment;
- b) X-ray equipment and systems;
- c) MRIs and CT scans; and
- d) laser equipment.

\*The definitions for Medical electrical equipment (MEE) and Medical electrical system (MES) can be found in SPE-3000-15 Section 3 Definitions.